



warrington
certification

Exova (UK) Limited trading as
Warrington Certification
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 646 669
W: www.warringtoncertification.com
E: etass@exova.com



Member of
www.eota.eu

European Technical Assessment

ETA 11/0481
of 01/05/12

General Part

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: Warrington Certification Limited

Trade name of the construction product	HENSOTHERM® 410 KS
Product family to which the construction product belongs	35. Fire Protective Products Reactive Coating for the Fire Protection of Steel Elements
Manufacturer	Rudolf Hensel GmbH Lauenburger Landstr 11, D-21039 Bornsen, Germany
Manufacturing plant(s)	Rudolf Hensel GmbH Lauenburger Landstr 11, D-21039 Bornsen, Germany
This European Technical Assessment contains	27 pages including 1 Annex which form an integral part of this assessment.
	Annex B and Annex C contain confidential information and are not included in the European Technical Assessment when that assessment is publicly available.
This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of	ETAG 018-1 edition April 2013 and ETAG 018-2 edition November 2011 used as European Assessment Document (EAD)
This version replaces:	The previous ETA with the same number issued on 01 st May 12

General Comments

1. This European Technical Assessment is issued by Warrington Certification Limited on the basis ETAG 018 Fire Protective Products Part 1: General and Part 2: Reactive Coatings For Fire Protection of Steel Elements, Used as European Assessment Document.
2. This European Technical Assessment is not to be transferred to manufacturers or agents of manufacturers other than those indicated on page 1, or manufacturing plants other than those indicated on page 1.
3. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.
4. Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.



1 SPECIFIC CONDITIONS OF THE EUROPEAN TECHNICAL ASSESSMENT

1 Technical Description of the Product

HENSOTHERM® 410 KS is a spray or brush/roller applied intumescent paint formulated for the fire protection of structural steel elements.

In accordance with ETAG 018-2 (foreword), HENSOTHERM® 410 KS may be considered as a reactive coating kit that includes one or more primers and/or topcoats (Option 2).

According to the manufacturer's declaration, the product specification has been compared with Annex XVII of REACH and the ECHA Candidate List of Substances of Very High Concern to verify that that it does not contain such substances.

2 Specification Of The Intended Use In Accordance With The Relevant EAD

The intended use of HENSOTHERM® 410 KS is to fire protect various sizes of structural steel 'H' or 'I' beams and columns for up to a fire resistance classification of R90, rectangular/square hollow columns, and circular hollow columns for up to a fire resistance classification of R60, and for design temperatures in the range of 350°C to 750°C.

The provisions made in this ETA are based on an assumed working life of the applied coating for the intended use of 10 years, provided that it is subject to appropriate use and maintenance according to manufacturer's instruction. The indications given on the intended working life cannot be interpreted as a guarantee given by the producer, but are to be used as a means for selecting the appropriate product in relation to the expected economically reasonable working life of the works.

HENSOTHERM® 410 KS has been assessed as being compatible with the following primers:

Primers				
Primer Reference	Generic Primer Type	Tested Nominal Primer DFT (mm)	Permitted Primer Thickness Range (mm)	
			Minimum*	Maximum
HENSOGRUND 1966E	Alkyd resin, solvent based	0.06	0.03	0.09
HENSOGRUND 2K	Two component epoxy resin, solvent based	0.07	0.035	0.105
HENSOGRUND 2K	Two component epoxy resin, solvent based (on Galvanised steel)	0.15	0.075	0.30
HENSOGRUND AQ	Water-based acrylic	0.07	0.035	0.105
HENSOGRUND AQ	Water-based acrylic (on Galvanised steel)	0.14	0.07	0.21

* Where the permitted theoretical minimum DFT is less than typical minimum dry film thickness recommended by manufacturer, the practical information given in product data sheet must be followed.

** The HENSOGRUND 2K and HENSOGRUND AQ primer system has been tested in accordance with the test procedures defined in ETAG 018-2 Clause 5.7.2.1 on galvanised steel substrates and passed the performance requirements for compatibility



HENSOTHERM® 410 KS has been assessed as being compatible with the following top coat:

Topcoats				
Topcoat Reference	Topcoat Type	Tested Nominal Topcoat DFT (mm)	Permitted Topcoat Thickness Range (mm)	
			Minimum*	Maximum
HENSOTOP 84	Acrylic resin solvent based	0.05	0.025	0.075
HENSOTOP 84 AQ	Acrylic resin water based	0.05	0.025	0.075
HENSOTOP SB	Acrylic resin solvent based	0.05	0.025	0.075
HENSOTOP WB	Acrylic resin water based	0.05	0.025	0.075
Teknocryl 100	Acrylic resin solvent based	0.05	0.025	0.075

* Where the permitted theoretical minimum DFT is less than typical minimum dry film thickness recommended by manufacturer, the practical information given in product data sheet must be followed.

HENSOTHERM® 410 KS has been assessed as having passed the requirements for durability according to ETAG 018 Part 2 with and without the following top coat:

Topcoat Reference	Durability Testing Conducted and Approved			
	Type Z2	Type Z1	Type Y	Type X
Without topcoat	✓	✓	-	-
HENSOTOP 84	✓	✓	-	-
HENSOTOP 84 AQ	✓	✓	-	-
HENSOTOP SB	✓	✓	✓	-
HENSOTOP WB	✓	✓	✓	-
Teknocryl 100	✓	✓	✓	-

HENSOTHERM® 410 KS was subjected to the identification testing in accordance with the methods of identification defined in Table 5.3 of ETAG 018 Part 2. Tests for 'fingerprinting' have been done as described in Annex E (Thermoanalytical analyses (TG) and Infrared spectroscopy analyses (IR)).



3 Performance Of The Product And References To The Methods Used For Its Assessment

Product: Reactive coating		Intended use: Fire protection of structural steel elements
Verification method	Product characteristic	Performance
MECHANICAL RESISTANCE AND STABILITY		
-	-	-
SAFETY IN CASE OF FIRE		
EN 13501-1	Reaction to fire	Class E
EN 13501-2	Fire resistance	Up to R90 (see Annex A)
HYGIENE, HEALTH AND THE ENVIRONMENT		
Manufacturer's declaration	Release of dangerous substances	Product specification doesn't contain dangerous substances given in Annex XVII of REACH and the ECHA Candidate List of Substances of Very High Concern
SAFETY IN USE		
-	-	-
PROTECTION AGAINST NOISE		
-	-	-
ENERGY ECONOMY AND HEAT RETENTION		
-	-	-
ASPECTS OF SERVICEABILITY, DURABILITY AND IDENTIFICATION		
ETAG 018 Part 2 Clause 5.7.1 and Clause 5.7.2.2	Durability and serviceability	<ul style="list-style-type: none"> Primer and top coat compatibility Type Z₂ durability Type Z₁ durability Type Y durability
ETAG 018 Part 2 Clause 5.7.3	Identification	Thermoanalytical analyses (TG) and Infrared spectroscopy analyses (IR)

In addition to the specific clauses relating to dangerous substances contained in this European technical assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.



4 Assessment And Verification Of Constancy Of Performance (Hereinafter AVCP) System Applied, With References To Its Legal base

According to the decision 1999/454/EC of the European Commission Decision of date 22 June 1999 on the procedure for attesting the conformity of construction products pursuant to Article 20(2) of Council Directive 89/106/EEC as regards fire stopping, fire sealing and fire protective products, the system of assessment and verification of constancy of performance (see Annex V to the Regulation (EU) No 305/2011) given in the following table apply:

Products	Intended uses	Level or Class	System
Fire protective products (including coatings)	Fire protection of steel elements	Any	1

5 Technical Details Necessary For The Implementation Of The AVCP System, As Provided For In The Applicable EAD.

The manufacturer shall exercise permanent internal control, record and evaluate the results of factory production in accordance with the provisions laid down in the "Control Plan" related to this European Technical Assessment. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. The production control system shall ensure that the product is in conformity with this European Technical Assessment.

The manufacturer may only use verified by Technical Assessment Body initial/raw/constituent materials stated in the technical documentations related to this European Technical Assessment.

The approved body shall retain the essential points of its actions referred to above and state the results obtained and conclusions drawn in a written report.


In cases where the provisions of the European technical assessment and its "Control Plan" are no longer fulfilled the certification body shall withdraw the Certificate of Constancy and inform the relevant authorities e.g. NANDO, EOTA.

The Table 8.1 in ETAG 018 Part 2 presents an example of the properties that shall be controlled and minimum frequencies of control. The exact test method and threshold have been laid down in the factory production control plan, operated by the manufacturer and deposited at Warrington Certification Limited.



Signatories


Responsible Officer
M.Jafarian* - Certification Engineer


Approved
J. Yuan* - Chief Engineer

* For and on behalf of Warrington Certification Limited.



Annex A - Product Performance: Fire Resistance

1. This Annex relates to the use of HENSOTHERM® 410 KS for the fire protection of 'H' or 'I' shaped beams and columns, and also the rectangular and circular hollow sections. The precise scope is given in Tables 1 to 19 which show the total dry film thickness of HENSOTHERM® 410 KS (excluding primer and top coat) required to provide classifications of R15 to R90 for 'H' or 'I' shaped beam or column section, and R60 for rectangular/square hollow column and circular hollow column sections for various design temperatures and section factors. A summary of the salient features of the testing and assessment are shown in this Annex.
2. The product is approved on the basis of:
 - i) Approval testing in accordance with the principles of EN 13381-8:2013.
 - ii) A design appraisal against this ETA adopting the graphical analysis defined in Annex E of EN 13381-8:2013
3. The data presented in the tables in this Annex refers to both beams (three-sided fire exposure) and columns (four sided exposure), and also to rectangular and circular hollow column sections.
4. The data shown is applicable to steel sections blast cleaned to ISO 8501-1 SA2.5 or equivalent and primed with the compatible primers and top coats listed in this ETA. The primer and top coat permitted dry film thickness are provided in the body of this European Technical Assessment.
5. The data for the 'I' and 'H' shaped columns applies also to other shaped steel sections that have re-entrant details such as channels, angles and tees.
6. HENSOTHERM® 410 KS has been exposed to the slowing heating regime defined in Annex A of EN 13381-8: 2013 and has satisfied the requirements.



Table 18: Circular and Rectangular Hollow Section Columns 45 Minutes

Section Factor up to m ⁻¹	Thickness (mm) Required for a Design Temperature of										
	350°C	400°C	450°C	500°C	520°C	550°C	575°C	600°C	650°C	700°C	750°C
47	-	-	-	-	-	-	-	-	0.219	0.207	0.203
50	-	-	-	-	-	-	-	-	0.219	0.207	0.203
55	-	-	-	-	-	-	-	-	0.219	0.207	0.203
60	-	-	-	-	-	-	-	-	0.219	0.207	0.203
65	-	-	-	-	-	-	-	-	0.230	0.207	0.203
70	-	-	-	-	-	-	-	-	0.254	0.207	0.203
75	-	-	-	-	-	-	-	-	0.277	0.207	0.203
80	-	-	-	-	-	-	-	-	0.300	0.222	0.203
85	-	-	-	-	-	-	-	-	0.324	0.238	0.203
90	-	-	-	-	-	-	-	-	0.347	0.253	0.203
95	-	-	-	-	-	-	-	-	0.371	0.268	0.203
100	-	-	-	-	-	-	-	-	0.394	0.283	0.203
105	-	-	-	-	-	-	-	-	0.417	0.298	0.207
110	-	-	-	-	-	-	-	-	0.441	0.313	0.210
115	-	-	-	-	-	-	-	-	0.464	0.328	0.214
120	-	-	-	-	-	-	-	-	0.487	0.343	0.218
125	-	-	-	-	-	-	-	-	0.511	0.358	0.221
130	-	-	-	-	-	-	-	-	0.534	0.374	0.225
135	-	-	-	-	-	-	-	-	-	0.389	0.228
140	-	-	-	-	-	-	-	-	-	0.404	0.232
145	-	-	-	-	-	-	-	-	-	0.419	0.236
150	-	-	-	-	-	-	-	-	-	0.434	0.239
155	-	-	-	-	-	-	-	-	-	0.449	0.243
160	-	-	-	-	-	-	-	-	-	0.464	0.246
165	-	-	-	-	-	-	-	-	-	0.479	0.250
170	-	-	-	-	-	-	-	-	-	0.495	0.254
175	-	-	-	-	-	-	-	-	-	0.510	0.257
180	-	-	-	-	-	-	-	-	-	0.525	0.261
185	-	-	-	-	-	-	-	-	-	0.540	0.264
190	-	-	-	-	-	-	-	-	-	0.555	0.268
195	-	-	-	-	-	-	-	-	-	-	0.285
200	-	-	-	-	-	-	-	-	-	-	0.357
205	-	-	-	-	-	-	-	-	-	-	0.430
210	-	-	-	-	-	-	-	-	-	-	0.502
215	-	-	-	-	-	-	-	-	-	-	-
220	-	-	-	-	-	-	-	-	-	-	-
225	-	-	-	-	-	-	-	-	-	-	-
230	-	-	-	-	-	-	-	-	-	-	-
235	-	-	-	-	-	-	-	-	-	-	-
240	-	-	-	-	-	-	-	-	-	-	-
245	-	-	-	-	-	-	-	-	-	-	-
250	-	-	-	-	-	-	-	-	-	-	-
255	-	-	-	-	-	-	-	-	-	-	-
260	-	-	-	-	-	-	-	-	-	-	-
265	-	-	-	-	-	-	-	-	-	-	-
270	-	-	-	-	-	-	-	-	-	-	-
275	-	-	-	-	-	-	-	-	-	-	-
280	-	-	-	-	-	-	-	-	-	-	-
285	-	-	-	-	-	-	-	-	-	-	-
290	-	-	-	-	-	-	-	-	-	-	-
295	-	-	-	-	-	-	-	-	-	-	-
300	-	-	-	-	-	-	-	-	-	-	-
305	-	-	-	-	-	-	-	-	-	-	-
310	-	-	-	-	-	-	-	-	-	-	-
315	-	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-	-
325	-	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-	-
335	-	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-	-
345	-	-	-	-	-	-	-	-	-	-	-
350	-	-	-	-	-	-	-	-	-	-	-
355	-	-	-	-	-	-	-	-	-	-	-
360	-	-	-	-	-	-	-	-	-	-	-
365	-	-	-	-	-	-	-	-	-	-	-
370	-	-	-	-	-	-	-	-	-	-	-
375	-	-	-	-	-	-	-	-	-	-	-
380	-	-	-	-	-	-	-	-	-	-	-
385	-	-	-	-	-	-	-	-	-	-	-
390	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only.



Table 19: Circular and Rectangular Hollow Section Columns 60 Minutes

Section Factor up to m ⁻¹	Thickness (mm) Required for a Design Temperature of										
	350°C	400°C	450°C	500°C	520°C	550°C	575°C	600°C	650°C	700°C	750°C
47	-	-	-	-	-	-	-	-	-	-	0.209
50	-	-	-	-	-	-	-	-	-	-	0.209
55	-	-	-	-	-	-	-	-	-	-	0.209
60	-	-	-	-	-	-	-	-	-	-	0.209
65	-	-	-	-	-	-	-	-	-	-	0.220
70	-	-	-	-	-	-	-	-	-	-	0.242
75	-	-	-	-	-	-	-	-	-	-	0.265
80	-	-	-	-	-	-	-	-	-	-	0.288
85	-	-	-	-	-	-	-	-	-	-	0.310
90	-	-	-	-	-	-	-	-	-	-	0.333
95	-	-	-	-	-	-	-	-	-	-	0.355
100	-	-	-	-	-	-	-	-	-	-	0.378
105	-	-	-	-	-	-	-	-	-	-	0.401
110	-	-	-	-	-	-	-	-	-	-	0.423
115	-	-	-	-	-	-	-	-	-	-	0.446
120	-	-	-	-	-	-	-	-	-	-	0.469
125	-	-	-	-	-	-	-	-	-	-	0.491
130	-	-	-	-	-	-	-	-	-	-	0.514
135	-	-	-	-	-	-	-	-	-	-	0.537
140	-	-	-	-	-	-	-	-	-	-	-
145	-	-	-	-	-	-	-	-	-	-	-
150	-	-	-	-	-	-	-	-	-	-	-
155	-	-	-	-	-	-	-	-	-	-	-
160	-	-	-	-	-	-	-	-	-	-	-
165	-	-	-	-	-	-	-	-	-	-	-
170	-	-	-	-	-	-	-	-	-	-	-
175	-	-	-	-	-	-	-	-	-	-	-
180	-	-	-	-	-	-	-	-	-	-	-
185	-	-	-	-	-	-	-	-	-	-	-
190	-	-	-	-	-	-	-	-	-	-	-
195	-	-	-	-	-	-	-	-	-	-	-
200	-	-	-	-	-	-	-	-	-	-	-
205	-	-	-	-	-	-	-	-	-	-	-
210	-	-	-	-	-	-	-	-	-	-	-
215	-	-	-	-	-	-	-	-	-	-	-
220	-	-	-	-	-	-	-	-	-	-	-
225	-	-	-	-	-	-	-	-	-	-	-
230	-	-	-	-	-	-	-	-	-	-	-
235	-	-	-	-	-	-	-	-	-	-	-
240	-	-	-	-	-	-	-	-	-	-	-
245	-	-	-	-	-	-	-	-	-	-	-
250	-	-	-	-	-	-	-	-	-	-	-
255	-	-	-	-	-	-	-	-	-	-	-
260	-	-	-	-	-	-	-	-	-	-	-
265	-	-	-	-	-	-	-	-	-	-	-
270	-	-	-	-	-	-	-	-	-	-	-
275	-	-	-	-	-	-	-	-	-	-	-
280	-	-	-	-	-	-	-	-	-	-	-
285	-	-	-	-	-	-	-	-	-	-	-
290	-	-	-	-	-	-	-	-	-	-	-
295	-	-	-	-	-	-	-	-	-	-	-
300	-	-	-	-	-	-	-	-	-	-	-
305	-	-	-	-	-	-	-	-	-	-	-
310	-	-	-	-	-	-	-	-	-	-	-
315	-	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-	-
325	-	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-	-
335	-	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-	-
345	-	-	-	-	-	-	-	-	-	-	-
350	-	-	-	-	-	-	-	-	-	-	-
355	-	-	-	-	-	-	-	-	-	-	-
360	-	-	-	-	-	-	-	-	-	-	-
365	-	-	-	-	-	-	-	-	-	-	-
370	-	-	-	-	-	-	-	-	-	-	-
375	-	-	-	-	-	-	-	-	-	-	-
380	-	-	-	-	-	-	-	-	-	-	-
385	-	-	-	-	-	-	-	-	-	-	-
390	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only.

